

Rudi Karpf

ete.a Ingenieurgesellschaft für Energie und Umweltengineering & Beratung mbH

Technical University Mittelhessen

13th Specialized International Conference Waste to Energy 2022 28. and 29. March, Prague (Cz) – Clarion Congress Hotel Prague









Motivation and Background





On December 3, 2019, the WI BREF was published in the EU Official Journal

The implementation in national law takes place primarily via the 17th BImSchV, but also in an administrative regulation adapted to the TA Luft and the annexes to the Wastewater Ordinance

Since the presentation of compliance costs is a central point in communication with the Regulatory Control Council a determination of the possible follow-up costs should already be carried out in the run-up to the amendment process





The consequential costs resulting from the tightening of limit values for airborne emissions must be determined

Existing municipal waste (incl. RDF), sewage sludge, hazardous waste and biomass incineration plants (waste wood) are considered for two limit value scenarios.

The upper values of the BAT associated emission bandwidth are to be assumed for Scenario 1 and the medians of the ranges (daily mean values) for Scenario 2, with the respective exceptions for the parameter mercury





| parameter | unit | existing emission limits 17. BlmSchV | emission limits szenario 1 | emission limits szenario 2 | monitoring frequenz | kind of average values |
|---|---------------------------|--|----------------------------------|----------------------------------|------------------------|------------------------------|
| dust | mg/m^3 STP dry | 5 | 5 | 3,5 | continually | DAV |
| HCI | mg/m ³ STP dry | 10 | 8 | 5 | continually | DAV |
| HF | mg/m ³ STP dry | 1 | 0,9 | 0,9 | continually | DAV |
| NO _x (SCR) | mg/m ³ STP dry | 150 | 150 | 100 | continually | DAV |
| SO _x as SO ₂ | mg/m ³ STP dry | 50 | 40 | 22,5 | continually | DAV |
| Hg | mg/m ³ STP dry | 0,05 | 0,035 | 0,02 | continually | HHAV |
| | | 0,03 | 0,01 | 0,01 | continually | DAV |
| | | 0,01 | 0,005 | 0,005 | continually | JAV |
| NH ₃ | mg/m ³ STP dry | 10 | 10 | 6 | continually | DAV |
| со | mg/m ³ STP dry | 50 | 50 | 30 | continually | DAV |
| Cd + Tl | mg/m ³ STP dry | 0,05 | 0,02 | 0,0125 | every 6 month | DAV |
| ∑Sb+As+Pb+Cr +Co+Cu+Mn+Ni +V + (Sn) | mg/m ³ STP dry | 0,5 | 0,3 | 0,155 | 1 | DAV |
| PCDD/F | ng ⊩тео /m³, | 1 | 0,06 | 0,035 | every 6 month | DAV |
| | STP dry | | 0,08 | 0,045 | monthly | DAV |
| PCDD/F + | ng who-тео | 0.1 | 0,08 | 0,045 | every 6 month | DAV |
| PCBs | $/m^3$, STP dry | 0,1 | 0,1 | 0,055 | monthly | DAV |
| TVOC / C _{ges.} | mg/m^3 STP dry | 10 | 10 | 6,5 | continually | DAV |

ete.a











method



- 13th International Conference Waste to Energy 2022, Prague
 - Questionnaires were used to ask the operators for current emission data in the context of the plant technology



- 210 existing plants in Germany were considered, of which 96 were municipal waste (including RDF), 28 were sewage sludge and 30 were hazardous waste incineration plants and 56 were biomass plants
- In addition to available process schemes and published emission values, the following plant data was recorded:
 - Number of emission control lines
 - Waste mass flow
 - Amount of fluegas
 - The co-incineration of sewage sludge
 - Additives and processes for the separation of acidic pollutant gases
 - Additives and processes for removing heavy metals, dioxins and furans
 - Methods and auxiliary materials for denitrification
 - type of combustion

Based on this data, an assessment of emissions compliance for the two specified scenarios was carried out





13th International Conference Waste to Energy 2022, Prague

Investment costs for retrofit

| | Action | | Costs and/or | Unit | |
|---|---|-----------|--------------|------------------------|--|
| | | | consumption | | |
| | General process optimization | | 150.000 | [€] | |
| | Retrofit residue recirculation | | 600.000 | [€] | |
| | Retrofit "Police Scrubber" | | 1.000.000 | [€ at 20.000 m³ / h] | |
| | Retrofit SNCR | | 600.000 | [€] | |
| | Addition of MinPlus | | 400.000 | [€] | |
| | Optimization of the wet scrubber (tray) N ₂ O-Analyzer New fabric filter Optimization of are specified with a | | 1.200.000 | [€ at 100.000 m³ / h] | |
| | | | 80.000 | [€] | |
| | | | 2.000.000 | [€ at 190.000 m³ / h] | |
| | | | 300.000 | [€] | |
| New fabric filter Optimizet Por measures that are specified with a For measures that are specified with a volume flow reference, the system-speci volume flow reference, the system-speci volume flow absolute and 40% linear costs are 60% absolute and 40% linear the basic volume flow | | to | 400.000 | [€] | |
| | | 10 | 1.300.000 | [€ bei 190.000 m³ / h] | |
| | | 5.400.000 | | [€ bei 190.000 m³ / h] | |
| | | 1.000 | | [€ / Mg] | |
| | | 0,4 | | [g / m³] | |
| | Switch to sodium bicarbonate | | 600.000 | [€] | |
| | Optimization of the activated carbon dosage | | 50.000 | [€] | |
| | Additional dosage of sodium bicarbonate | | 400.000 | [€] | |
| | | | | | |



Recurring costs through the procurement and disposal of additives for the separation of acidic pollutant gases


Raw gas concentrations of the individual plant classes [mg/m³]

| | SO _x | HCI | HF |
|-----------------|-----------------|-------|-----|
| Municipal waste | 650 | 1.500 | 14 |
| sewage sludge | 3.000 | 150 | 10 |
| hazardous waste | 1.500 | 4.000 | 175 |
| biomass | 350 | 220 | 12 |

Additive costs for the separation of acidic pollutant gases [€/Mg]

| Sodiumbicarbonat | 280 |
|------------------|-----|
| Calciumhydroxid | 120 |
| Sodium (50 %) | 560 |








Results



ete.a

13th International Conference Waste to Energy 2022, Prague

Evaluated and non-evaluable of incineration plants in Germany




- Total flue gas volume flow of existing evaluated plants
- Extrapolated total flue gas volume flow of existing plants

Flue gas flow [million m^3/h]



General retrofit requirements

Percentage of biomass plants with retrofitting requirements



■ No requirements ■ Requirements in scenario 2 only ■ Requirements in scenario 1 and 2






Need for retrofitting according to individual measures

Percentage of sewage sludge incineration plants with respective retrofitting requirements

Percentage of municipal waste incineration plants (incl. RDF) with respective retrofitting

requirements

Percentage of biomass plants with respective retrofitting requirements



Scenario 2 Scenario 1






ete.a

13th International Conference Waste to Energy 2022, Prague

Recurring follow-up costs (extrapolated) of the system stock for the respective scenarios [€/a]


Recurring costs for all excisting plants (extrapolated)



14 von 18



One-off follow-up costs (extrapolated) of the system stock for the respective scenarios [€]











16 von 18



The recognized recurring follow-up costs amount to 24.6 Mio. €/a in scenario 1 and increase by a factor of 3.7 to 91.5 Mio. €/a in scenario 2.




These costs are mainly caused by the additional procurement and disposal of additives, which become necessary due to stricter emission limit for the acidic pollutant gases HCI, SOx and HF

The one-time investment costs are 84.9 Mio. € in Scenario 1 and 488.4 Mio. € in Scenario 2, which corresponds to an increase by a factor of 4.7.

While retrofitting measures with regard to acidic pollutant gases are the biggest cost drivers in the first scenario, in the second scenario it is the retrofitting for catalytic reduction of NOx.

Since the almost five-fold increase in costs between Scenario 1 and Scenario 2 is due to the retrofitting of denitrification measures, the political discussion on the emission limits according to Scenario 2 in the context of the NOx emissions from 17th BImSchV systems (0.04%) are managed.



Thank you for your attention!



18 von 18